

Repair/Replacement of old pipe line of Girls Hostel toilets of JC Bose University.

Sr. No	Item Name	Qty.	Unit	Basic Price in Rs.	Amount
1.	Providing and fixing Chlorinated Polyvinyl Chloride (CPVC) pipes, having thermal stability for hot & cold water supply, including all CPVC plain & brass threaded fittings, including fixing the pipe with clamps at 1.00 m spacing. This includes jointing of pipes & fittings with one step CPVC solvent cement and testing of joints complete as per direction of Engineer in Charge. HSR 22.85				
	20 mm nominal outer dia Pipes	115.90	Mtr.		
	25 mm nominal outer dia Pipes	73.20	Mtr.		